

Date: March 26, 2026

To: Bidders of Record

Cc: Laura McGrath, Skokie Public Library
Suzy Rodela-Sulik, Skokie Public Library

Re: 2nd Floor AHU Replacement
Skokie Public Library
5215 Oakton St.

This Addendum forms a part of the Bidding Documents and amends the original documents dated March 11, 2026.

Acknowledge receipt of this addendum in the space provided on Bid Form. Failure to do so may subject bidder to disqualification.

RFI RESPONSES

1. M001 – Fans Note 2 calls out EC Motors (ECM) are not permitted. In order to meet or exceed the project requirements, will EC Fans be considered, perhaps as an alternate? This affects specification section 23 7300 – 2.8 FAN SECTION.
 - a. ANSWER: Contractor may submit pricing with fans utilizing EC motors as a voluntary alternate for consideration.

2. Specification section 23 7300 – 2.4.D – Will 8 gauge aluminum checker plate be acceptable in lieu of 5 gaust?
 - a. ANSWER: Yes, this is acceptable.

END ADDENDUM